REV.	ZONE	ECN NO.	DATE	BY	CKR	APP.

Phil Pape, Controls Division 11/8/2002 11:05 AM 930A_rack.dwg



FRONT VIEW



REAR VIEW





NOTE:

NO REAR ACCESS TO RACK

-3	-2	-1	REF DESIGNATOR	ITEM NO.	DESCRIPTION	MAT'L DWG NO.,BNL NO.
		1	A	13	BUFFERED MADC A/D I/O PANEL	94028670
		1	N/A	12	BUFFERED MADC POWER SUPPLY	940288808
		1	TB1	11	37 DSUB to TERMINAL BLOCK (PHOENIX)	
		1		10	AC RESET ASSEMBLY	D09-E2653
		1		9	1U x 19" BLANK PANEL (PREMIER METAL ARP-119-553)	
		1		8	4U RACK FAN ASSEMBLY	
		1		7	6U x 19" BLANK PANEL (PREMIER METAL ARP-1019-553)	
		1	X	6	1U PANEL WITH 12 BNC BULKHEAD CONNECTORS	
		1		5	POWER SUPPLY GROUP ELECTRONIC CHASSIS	
		1		4	6U VERO CHASSIS (POWER SUPPLY GROUP ELECTRONICS)	
		1		3	1U GROMMET PANEL	
		1		2	VME CHASSIS CST.930A.PS1	94028399
		1	RK 4959	1	19 RACK, 70"H RACK SPACE	

QTY REQD

INTERPRET IN GENERAL ACCORDANCE WITH ASME Y14.24M-1989

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES

DECIMAL TOLERANCES
.X ±.030
.XX ±.015
.XXX ±.005
ANGULAR TOLERANCE
± .5°

NA FINISH

BREAK SHARP EDGES
MAX. XX MIN. XX

OUTSTANDING ECN

Q.A. CATEGORY A-3

		DATE
DRAWN BY	PAPE	11/08/2002
CHECKED BY		
DESIGN APPROVAL		
ENGINEER APPROVAL		
SUPVR. APPROVAL		

NEXT ASSEMBLY

BROOKHAVEN NATIONAL LABORATORY
UPTON, N.Y. 11973
C-A CONTROLS
BLDG 930A
RACK 4959 ASSEMBLY

SIZE D | DRAWING NUMBER | REV. A

MATERIAL: ——— SCALE: FULL WEIGHT: – SHEET 1 OF 1

*AUTOCAD